



October 20, 2004

Technical Specification 5.6.8

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

Palisades Nuclear Plant  
Docket 50-255  
License No. DPR-20

2004 Steam Generator Tube Surveillance Report – Tubes Plugged

Nuclear Management Company, LLC completed an inservice inspection of the Palisades steam generator tubes on October 9, 2004. Palisades Technical Specification 5.6.8.a requires that the number of tubes plugged in each steam generator be reported within fifteen days following the completion of the inservice inspection.

Fifteen tubes were plugged in steam generator E-50A and three tubes were plugged in steam generator E-50B. The total number of tubes plugged in steam generator E-50A is 380. The total number of tubes plugged in steam generator E-50B is 363.

Summary of Commitments

This letter contains no new commitments and no revisions to existing commitments.

Daniel J. Malone  
Site Vice President, Palisades Nuclear Plant  
Nuclear Management Company, LLC

A047

Document Control Desk

Page 2

CC Administrator, Region III, USNRC  
Project Manager, Palisades, USNRC  
Resident Inspector, Palisades, USNRC